

广州检验检测认证集团有限公司
 国家加工食品质量检验中心（广东）
 检验检测报告



中国认可
 国际互认
 检测
 TESTING
 CNAS L10314



№食检2021-09-5269 样单号：2114698



第 1 页 共 2 页

产品名称	直饮水	商标	----	规格型号	----
生产日期/批号	----	等级	----	限期使用日期 (保质期)	----
来样方式	委托单位送检	样品 状况	正常	检验环境 说明	按标准要求
抽(送)样日期	2021年09月28日	验讫 日期	2021年10月11日	样品数量	10L (2桶)
检验类别	委托检验检测				
委托单位	广东外语外贸大学南国商学院				
标称生产单位	----				
依据	CJ 94-2005《饮用净水水质标准》				
综合检验结论	所检项目符合CJ 94-2005标准要求。				



签发日期：2021年10月12日

此处未盖“检验检测专用章”本报告无效。

序号	检验项目	单位	标准要求	检验结果	单项评价
			----	----	
1	色	度	≤5	<5, 无异色	符合
2	浑浊度	NTU	≤0.5	<0.5	符合
3	臭和味	----	无异臭异味	符合标准要求	符合
4	肉眼可见物	----	无异物	未检出	符合
5	pH	----	6.0~8.5	6.7	符合
6	耗氧量 (COD _{Mn} , 以 O ₂ 计)	mg/L	≤2.0	0.36	符合
7	砷	mg/L	≤0.01	<0.001	符合

签发： 罗曼妮 职务：批准员

扫码查验
 报告真伪



WWW.GJGQT.COM

防伪查询码：27BC047CF69B28B8
 (0628/2021.10.12)

地址：广州市番禺区石楼潮田工业区珠江路1-2号

广州检验检测认证集团有限公司
 国家加工食品质量检验中心（广东）
 检 验 结 果



中国认可
 国际互认
 检测
 TESTING
 CNAS L10314



(02020) 国认监认字(270)号

№ 食检2021-09-5269 样单号：2114698

第 2 页 共 2 页

序号	检验项目	单位	标准要求	检验结果	单项评价
			----	----	
8	铅	mg/L	≤0.01	<0.001	符合
9	氯仿	mg/L	≤0.03	0.0176	符合
10	四氯化碳	mg/L	≤0.002	未检出 (最低检测质量浓度：0.1 μg/L)	符合
11	细菌总数	CFU/mL	≤50	未检出	符合
12	总大肠菌群	MPN/100mL	不得检出	未检出	符合
13	粪大肠菌群	MPN/100mL	不得检出	未检出	符合

签发： 罗曼妮 职务：批准员

扫码查验
 报告真伪



地址：广州市番禺区石楼潮田工业区珠江路1-2号

WWW.GJGQT.COM
 防伪查询码：27BC047CF69B28B8
 (0628/2021.10.12)



声 明

DECLARATION

- 1、本报告无本公司/中心检验检测专用章无效，无签发人签字无效。

The test report shall be invalid without being affixed by Specific Seal authorized by GTTC or the signature of authorized signer.

- 2、本报告涂改增删无效。

The test report shall be invalid if any parts of it being supplemented deleted or altered.

- 3、未经本公司/中心书面批准不得部分复制本报告，全部复制除外。

The report shall not be duplicated separately or partly, without prior written permission approved by GTTC, except duplicated in full version.

- 4、客户提供的信息（包括样品信息），本公司/中心不对其真实性负责。对送检样品，本报告仅对来样负责。

As for the tested sample(s) supplied by applicant who shall be in responsibility with the authenticity and preciseness of sample(s) information or any other information associated, GTTC shall not be responsible for those mentioned above, and this report shall only be responsible for the result of tested sample supplied by the applicant.

- 5、委托方不得擅自使用本报告中的结果进行不当宣传。

Any propaganda through citing the test report result or any other parts of the test report as provement or evidence by applicant shall be regarded as an improper way and shall be forbidden.

- 6、若对本报告有异议，应于收到报告后 15 日内向本公司/中心提出，逾期将视为认可本报告。

Any dispute of the report shall be raised to GTTC in duration of 15 days when report is received; otherwise both parties of contract shall be regarded as to reach an agreement of the report.

- 7、若本公司/中心所出具本报告未标注资质认定标志，则出具的检验数据、结果仅供委托方参考，对社会不具有证明作用。

If report is affixed with no qualification and identification mark, then the inspection data and results issued are only for the purpose of reference of client and have no proving effect to the social public.

业务电话/ Business hotline: 020-31002705, 020-31002695, 020-31002527

报告书质量异议处理电话/ Complaint hotline: 020-84659599